

**Burlington High School**

52 Institute Road  
 Burlington, Vermont

**Indoor Air Sampling Summary for PCBs  
 Sampling Results Summary for Buildings A and B**

**Date Sampled:** September 2-3, 2020

**Laboratory Report Received:** September 10, 2020

Field Sample No.	Sample Description	Results
<b>Building A</b>		
A-106-25		260 ng/m <sup>3</sup>
A-Glock-31	Girls' Locker Room	14 ng/m <sup>3</sup>
A-205A-32	Custodial Break Room	170 ng/m <sup>3</sup>
A-203-33	Aviation Shop	81 ng/m <sup>3</sup>
A-ER-East-34	Weight Room	12 ng/m <sup>3</sup>
A-103-35		38 ng/m <sup>3</sup>
A-Gym-46	Gymnasium	1.1 ng/m <sup>3</sup>
A-318-13	Wood Shop	38 ng/m <sup>3</sup>
A-Café-15	Cafeteria	8.2 ng/m <sup>3</sup>
A-Café-HF-54	Cafeteria	4 ng/m <sup>3</sup>
A-312E-11	Kitchen	12 ng/m <sup>3</sup>
A-Aud-14	Auditorium	17 ng/m <sup>3</sup>
A-304-12	Office	24 ng/m <sup>3</sup>
A-415-08	On Top Program	22 ng/m <sup>3</sup>
<b>Building B</b>		
B-103-09	Library	47 ng/m <sup>3</sup>
B-104B-17	IT	27 ng/m <sup>3</sup>
B-103C-23	Library Office	270 ng/m <sup>3</sup>
B-209-16	Foreign Language Classroom	110 ng/m <sup>3</sup>
B-202-38	Art Room	100 ng/m <sup>3</sup>
<b>Building C</b>		
C-102-10	Education Classroom 102	130 ng/m <sup>3</sup>

EPA Advisory concentrations Website:

<https://19january2017snapshot.epa.gov/pcbs/exposure-levels-evaluating-polychlorinated-biphenyls-pcbs-indoor-school-air.html#:~:text=EPA%20recommends%20that%20the%20concentrations%20of%20PCBs%20in,can%20be%20calculated%20if%20sufficient%20data%20are%20available>

A and Building Laboratory Results link: [https://www.bsdtv.org/wp-content/uploads/2020/09/rfm\\_20I0221-Contest\\_Final-FINAL-09-10-20-1536.pdf](https://www.bsdtv.org/wp-content/uploads/2020/09/rfm_20I0221-Contest_Final-FINAL-09-10-20-1536.pdf)

A-E Building diagram of sample locations and results: [https://www.bsdtv.org/wp-content/uploads/2020/09/Appendix-D\\_rfm\\_revised\\_Burlington\\_Sample-Results\\_20200910.pdf](https://www.bsdtv.org/wp-content/uploads/2020/09/Appendix-D_rfm_revised_Burlington_Sample-Results_20200910.pdf)

**Burlington High School**  
52 Institute Road  
Burlington, Vermont

**Indoor Air Sampling Summary for PCBs**  
**Sampling Results Summary for Building F**

**Date Sampled:** September 2-3, 2020

**Report Received:** September 9, 2020

<b>Field Sample No.</b>	<b>Sample Description</b>	<b>Results</b>
<b>Building F</b>		
F-312-06	Child Care Center – Room F-312	720 ng/m <sup>3</sup>
F-312-Dup-07	Child Care Center – Room F-312	640 ng/m <sup>3</sup>
F-312-HF-51	Child Care Center – Room F-312	160 ng/m <sup>3</sup>
F-304-18	Health Sciences – Room F-304	400 ng/m <sup>3</sup>
F-309-26	Criminal Justice – Room F-309	760 ng/m <sup>3</sup>
F-205-30	Metals Shop Jewelry – Room F-205	1300 ng/m <sup>3</sup>
F-210-28	Welding Shop – Room F-210	5800 ng/m <sup>3</sup>
F-214-21	Construction Trades Shop – Room F-214	5300 ng/m <sup>3</sup>
F-103-19	Automotive Shop – Rom F-103	1900 ng/m <sup>3</sup>

EPA Advisory concentrations Website:

<https://19january2017snapshot.epa.gov/pcbs/exposure-levels-evaluating-polychlorinated-biphenyls-pcbs-indoor-school-air.html#:~:text=EPA%20recommends%20that%20the%20concentrations%20of%20PCBs%20in,can%20be%20calculated%20if%20sufficient%20data%20are%20available>

F Building Laboratory Results link [https://www.bsdtv.org/wp-content/uploads/2020/09/20I0220-Contest\\_Final-FINAL-09-09-20-1606.pdf](https://www.bsdtv.org/wp-content/uploads/2020/09/20I0220-Contest_Final-FINAL-09-09-20-1606.pdf)

F Building diagram of sample locations and results [https://www.bsdtv.org/wp-content/uploads/2020/09/rlm\\_Building-F-from-Appendix-D\\_rlm\\_revised\\_Burlington\\_Proposed-Sampling-Loca..pdf](https://www.bsdtv.org/wp-content/uploads/2020/09/rlm_Building-F-from-Appendix-D_rlm_revised_Burlington_Proposed-Sampling-Loca..pdf)